

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 04/12/2013  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>155019</b>		(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>03</b>  B. WING _____		(X3) DATE SURVEY COMPLETED  <b>04/04/2013</b>	
NAME OF PROVIDER OR SUPPLIER  <b>GARDEN VILLA - BLOOMINGTON</b>				STREET ADDRESS, CITY, STATE, ZIP CODE <b>1100 S CURRY PK BLOOMINGTON, IN 47403</b>			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
K 000	<p><b>INITIAL COMMENTS</b></p> <p>A Life Safety Code and Environmental Preoccupancy Survey for the Certification of the New Dining/Lounge area on Station 3 and the renovated Sunroom on Station 1 was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a).</p> <p>Survey Date: 04/04/13</p> <p>Facility Number: 000007 Provider Number: 155019 AIM Number: 100275040</p> <p>Surveyor: Phillip Komsiski, Life Safety Code Specialist</p> <p>At this Life Safety Code and Environmental Preoccupancy survey, Garden Villa - Bloomington was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety from Fire, and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 18, New Health Care Occupancies and 410 IAC 16.2-3.1-19 Environment and Physical Standards of the Indiana Health Facilities Rules for Comprehensive care facilities for the New Dining/Lounge area on Station 3 and the renovated Sunroom on Station 1.</p> <p>This one story facility was determined to be of Type V (111) construction and was fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors, spaces open to the corridors and hard wired smoke detectors in resident rooms on Unit 4, Unit 5 and Unit 6 and battery powered smoke detectors in</p>			K 000			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (\*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES  
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 04/12/2013  
FORM APPROVED  
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:  <b>155019</b>	(X2) MULTIPLE CONSTRUCTION A. BUILDING <b>03</b>  B. WING _____		(X3) DATE SURVEY COMPLETED  <b>04/04/2013</b>
NAME OF PROVIDER OR SUPPLIER  <b>GARDEN VILLA - BLOOMINGTON</b>			STREET ADDRESS, CITY, STATE, ZIP CODE <b>1100 S CURRY PK BLOOMINGTON, IN 47403</b>		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETION DATE	
K 000	Continued From page 1 resident rooms on Unit 1, Unit 2 and Unit 3. The facility has a capacity of 224 and had a census of 181 at the time of this survey.  All areas where the residents have customary access were sprinklered. All areas providing facility services were sprinklered except for one garage used for facility storage.  Quality Review by Robert Booher, Life Safety Code Specialist-Medical Surveyor on 04/11/13.	K 000			